



Product Service

Attestation of Conformity

No. N8A 001639 0036 Rev. 04

Holder of Certificate: **SUNRISE POWER TECHNOLOGY CO., LTD**

The junction of Liaoyuan Rd&Linqun Rd,Feidong
Xincheng Develop Distrct,Hefei City,Anhui
Province ,China

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
[Mono Crystalline Silicon Photovoltaic (PV) Module(s)]

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290203011305A

Date, 2021-07-08

(Symbol Zhao)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 001639 0036 Rev. 04

Model(s): SUNxxx-72MD-H6S (xxx=420-455, in steps of 5);
 SUNxxx-66MD-H6S (xxx=395-415, in steps of 5);
 SUNxxx-60MD-H6S (xxx=350-380, in steps of 5);
 SUNxxx-78MD-HFS (xxx=430-445, in steps of 5);
 SUNxxx-72MD-HFS (xxx=400-415, in steps of 5);
 SUNxxx-60MD-HFS (xxx=330-345, in steps of 5).
 SUNxxx-72MD-H8S (xxx=525-550, in steps of 5);
 SUNxxx-66MD-H8S (xxx=480-505, in steps of 5);
 SUNxxx-60MD-H8S (xxx=440-455, in steps of 5);
 SUNxxx-54MD-H8S (xxx=390-410, in steps of 5).
 xxx stands for rated output power at STC.

SUNxxx-xxMD-H6S, SUNxxx-xxMD-HFS and
 SUNxxx-xxMD-H8S series are bifacial modules. The "rated
 output power at STC" is generated only by front side.

Parameters:

Safety class:	Class II
Max. system voltage:	1500 V d.c.
Construction:	Framed, with Junction box, Cable and Connectors

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-2:2018